



Wyoming Cheyenne Adjutant General's Office

Facility and Location

The Cheyenne Adjutant General's Office is composed of an office in the City of Cheyenne that houses support staff. It does not now and has never had any ranges around it.

Media Sampled and Findings

Drinking Water — In 2011, two of two samples detected perchlorate at 0.05 and 0.08 ppb.

Appropriate Actions

Not Applicable. All samples were below the EPA and DoD Preliminary Remediation Goal of 15 ppb.